


SOLAR COLLECTOR CERTIFICATION AND RATING  SRCC OG-100	<u>CERTIFIED SOLAR COLLECTOR</u> SUPPLIER: Beijing Sunda Solar Energy Technology Co Ltd No. 3 Hua Yuan Road Haidian District Beijing, 100083 MODEL: SUNDA SEIDO1-16 COLLECTOR TYPE: Tubular CERTIFICATION #: 100-2004-001B
--	--

COLLECTOR THERMAL PERFORMANCE RATING							
Megajoules Per Panel Per Day				Thousands of Btu Per Panel Per Day			
CATEGORY (Ti-Ta)	CLEAR DAY 23 MJ/m ² ·d	MILDLY CLOUDY 17 MJ/m ² ·d	CLOUDY DAY 11 MJ/m ² ·d	CATEGORY (Ti-Ta)	CLEAR DAY 2000 Btu/ft ² ·d	MILDLY CLOUDY 1500 Btu/ft ² ·d	CLOUDY DAY 1000 Btu/ft ² ·d
A (-5 °C)	43	33	23	A (-9 °F)	41	31	21
B (5 °C)	41	31	21	B (9 °F)	39	29	19
C (20 °C)	37	27	17	C (36 °F)	35	26	16
D (50 °C)	32	22	12	D (90 °F)	30	21	11
E (80 °C)	26	16	6	E (144 °F)	25	15	6

A-Pool Heating (Warm Climate) B-Pool Heating (Cool Climate) C-Water Heating (Warm Climate) D-Water Heating (Cool Climate) E-Air Conditioning

Original Certification Date: March 4, 2004

COLLECTOR SPECIFICATIONS

Gross Area:	3.994 m ²	42.99 ft ²	Net Aperture Area:	3.619 m ²	38.96 ft ²
Dry Weight:	100.2 kg	221 lb	Fluid Capacity:	1.1 l	0.3 gal
Test Pressure:	1000 kPa	145 psig	Max. Oper. Temp.:	120 °C	248 °F

COLLECTOR MATERIALS

Frame:	Stainless Steel
Cover (Outer):	Glass Vacuum Tube
Cover (Inner):	None
Absorber Material:	Tube - Copper / Plate - Aluminum
Absorber Coating:	Sputtered aluminium nitride
Insulation (Side):	Vacuum
Insulation (Back):	Vacuum

PRESSURE DROP

Flow		Δ P	
ml/s	gpm	Pa	in H ₂ O
0	0.00	0	0.00
0	0.00	0	0.00
0	0.00	0	0.00

TECHNICAL INFORMATION

Efficiency Equation [NOTE: (P) = Ti-Ta]				Y Intercept	Slope
SI Units:	$\eta = 0.526 - 1.3253 (P)/I - 0.0042 (P)^2/I$			0.529	-1.697 W/m ² ·°C
IP Units:	$\eta = 0.526 - 0.2336 (P)/I - 0.0004 (P)^2/I$			0.529	-0.299 Btu/hr·ft ² ·°F

Incident Angle Modifier [(S) = 1/cos θ - 1, 0° ≤ θ ≤ 60°]	Model Tested:	2004001A
$K_{\alpha} = 1.0 + 0.3023 (S) - 0.3057 (S)^2$	Test Fluid:	Water
$K_{\alpha} = 1.0 + 0.00 (S)$ (Linear Fit)	Test Flow Rate:	36 ml/s 0.57 gpm

REMARKS: Collector tested with long axis of tubes oriented north-south. IAM perpendicular to the tubes is listed above. IAM parallel to the tubes = 1.0 - .08(S) or 1.0 + 0.0126(S) - 0.094(S)²

March, 2004

Certification must be renewed annually. For current status contact:

SOLAR RATING & CERTIFICATION CORPORATION

c/o FSEC ♦ 1679 Clearlake Road ♦ Cocoa, FL 32922 ♦ (321) 638-1537 ♦ Fax (321) 638-1010